

Certificate of Conformity

Product Conformity Scheme (PCS)-Type Test Certification

Australian Certification Services Pty Ltd hereby certifies that a sample of the products as identified in the listing below and submitted by;

Metal Manufactures Ltd

Gloucester Boulevard Port Kembla NSW 2505 AUSTRALIA

Has been examined and found to be in conformity with the requirements of the Standard/s referred to below;

Evaluated to: AS 1530.3:1999 Methods for fire tests on building materials, components and structures Part 3: Simultaneous determination of ignitability, flame propagation, heat release and smoke release

Manufacturer: K Flex Malaysia Sdn Bhd

Product Type: Elastomeric Insulation

Brand: K Flex ST

Product Description: Elastomeric Insulation (Black) Available in Tubes Pre Cut with Adhesive and Sheets Suitable for Use for all Applications Civil and Industrial that Require use of Insulation Material

Temperature Range: -40°C to 85°C

Thermal Resistance: Ignitability Index (0) Spread of Flame Index (0) Heat Evolved Index (0) Smoke Developed Index (3)

Test Report Identification: AWTA Product Testing (NATA 983/985/1356) Test Report Number 7-589565-CO date 04/03/2013 (10mm Flexible elastomeric foam) AS/NZS 1530.3:1999



Issue Date 12th February 2016
Initial Issue Date: 12th February 2016
Expiry Date: 11th February 2021

Paul Greig
General Manager

Certificate No.: 4025

This certificate remains the property of Australian Certification Services Pty Ltd

The Product Conformity Scheme (PCS)-Type Test Certification is a conformity assessment scheme based on ISO Guide 67 (system 1b)

