

Sample			Drain 3 Outlet	Drain 3 Outlet	Drain 3 Outlet	Drain 3 Outlet	Drain 3 Outlet	Drain 3 Outlet
Date Sampled			10/05/2022	18/05/2022	24/05/2022	31/05/2022	9/06/2022	22/06/2022
Type of sample	Units	PQL	Water	Water	Water	Water	Water	Water
1,2,3-trichlorobenzene	µg/L	1	<1	<1	<1	<1	<1	<1
TRH C6 - C9	µg/L	10	<10	<10	<10	<10	<10	<10
TRH C6 - C10	µg/L	10	<10	<10	<10	<10	<10	<10
TRH C10 - C14	µg/L	50	<50	<50	<50	<50	<50	<50
TRH C15 - C28	µg/L	100	<100	<100	<100	<100	<100	<100
TRH C29 - C36	µg/L	100	<100	<100	<100	<100	120	<100
Total +ve TRH (C10-C36)	µg/L	50	<50	<50	<50	<50	120	<50
TRH >C10 - C16	µg/L	50	<50	<50	<50	<50	<50	<50
TRH >C10 - C16less Naphthalene (F2)	µg/L	50	[NT]	<50	<50	[NT]	<50	<50
TRH >C16 - C34	µg/L	100	<100	<100	<100	<100	160	<100
TRH >C34 - C40	µg/L	100	<100	<100	<100	<100	<100	<100
Total +ve TRH (>C10-C40)	µg/L	50	<50	<50	<50	<50	160	<50
Naphthalene	µg/L	1	<1	<1	<1	<1	<1	<1
Acenaphthylene	µg/L	1	<1	<1	<1	<1	<1	<1
Acenaphthene	µg/L	1	<1	<1	<1	<1	<1	<1
Fluorene	µg/L	1	<1	<1	<1	<1	<1	<1
Phenanthrene	µg/L	1	<1	<1	<1	<1	<1	<1
Anthracene	µg/L	1	<1	<1	<1	<1	<1	<1
Fluoranthene	µg/L	1	<1	<1	<1	<1	<1	<1
Pyrene	µg/L	1	<1	<1	<1	<1	<1	<1
Benzo(a)anthracene	µg/L	1	<1	<1	<1	<1	<1	<1
Chrysene	µg/L	1	<1	<1	<1	<1	<1	<1
Benzo(b,j+k)fluoranthene	µg/L	2	<2	<2	<2	<2	<2	<2
Benzo(a)pyrene	µg/L	1	<1	<1	<1	<1	<1	<1
Indeno(1,2,3-c,d)pyrene	µg/L	1	<1	<1	<1	<1	<1	<1
Dibenzo(a,h)anthracene	µg/L	1	<1	<1	<1	<1	<1	<1
Benzo(g,h,i)perylene	µg/L	1	<1	<1	<1	<1	<1	<1
Benzo(a)pyrene TEQ	µg/L	5	<5	<5	<5	<5	<5	<5
Total +vePAH's	µg/L	1	NIL (+)VE	NIL (+)VE	NIL (+)VE	NIL (+)VE	NIL (+)VE	NIL (+)VE
pH	pH Units		7.7	8.2	8	8.3	8.2	7.8
Electrical Conductivity	µS/cm	1	560	750	470	1100	1600	1100