

CLASS 1

# Building Product Information Sheet

Product name:

SPK Valve Range

Product line (the product line from which the product is customised):

Ball Valves, Gate Valves, Universal Valves, Cistern Taps

Product description and its intended use (measurements, materials, usage):

The SPK Valve range is manufactured in accordance with WMTS 012:2018 and DZR AS 2345(except for gate valves) and meets the requirements of AS/NZS 4020 Materials in contact with drinking water.  
The SPK Valve range available sizes 15mm up to 100mm dependent on valve selection.  
Intended for use for plumbing applications hot and cold potable water.  
Further information refer to [www.mmbrands.co.nz](http://www.mmbrands.co.nz)

Product identifier (if applicable):

SPK/NZ+ DR Ball Valves M, M/F,TH, LH; SPK - Gate Valves M, M/F; Universal Valves M, M/F; Cistern Taps TP22CPCH/CPM/KIT2,TPMCT,

Place of manufacture:  Aotearoa New Zealand  Overseas

Legal and trading name of the manufacturer(s):

Manufactured under licence by Huaer Valve Co Ltd on behalf of MM Brands Ltd for SPK

Legal and trading name of the importer (if applicable):

MM Brands Ltd

Address for service:

STREET NAME 263 Ti Rakau Drive

SUBURB Burswood

CITY, COUNTRY Auckland NZ

POSTCODE 2013

Website:

[www.mmbrands.co.nz](http://www.mmbrands.co.nz)

Email address:

[sales@mmbrands.co.nz](mailto:sales@mmbrands.co.nz)

Phone No. (if applicable):

09 2740111

NZBN (if applicable):

9429040718897

Relevant Building Code clauses:

Durability B2.3.1(b)  
 Hazardous Building Materials F2.3.1  
 Water supplies G12.2

Statement on how the building product is expected to contribute to compliance:

**Durability B2.3.1(c)**  
 The SPK Valve range meets the 15 year performance requirement.

**Hazardous Building Materials F2.3.1**  
 The SPK Valve range does not give rise to harmful concentrations at the surface of the material where the material is exposed, or in the atmosphere of any space as per requirement F2.3.1

**Water Supplies G12.2**  
 The SPK Valve range meets the requirements of AS/NZS 4020 potable water standards and has components that wouldn't contaminate the water as per requirement G12.2.1. and is durable and fit for purpose as per requirement G12.2.2 and G12/VM1

- options for compliance set out in section 19 of the Act (regulations, acceptable solution, verification method)
- standard or technical document that describes the performance of the building product or the relevant specifications to which the building product was manufactured
- physical properties of the building product
- how the building product is intended to be used.

Limitations on the use of the building product:

As defined in the scope of the installation standards G12 and AS/NZS 3500  
Guidance of application limitations is also available at: [www.mbrands.com](http://www.mbrands.com)

Design requirements that would support the use of the building product:

Durability and Proven Performance.  
As defined in the scope of the installation standards G12 and AS/NZS 3500  
Guidance of design requirements is also available at: [www.mbrands.com](http://www.mbrands.com)

Installation requirements:

Installation shall be performed by licenced and competent installers.

Maintenance requirements:

The SPK Valve range requires no ongoing maintenance post commissioning.

Is the building product/building product line subject to warning or ban under section 26?: No

If yes, description of the warning or ban under section 26:

Date: 11 December 2023